

Certificate

On 26 March 2007 Eurofins Environment A/S received a sample of a wall paint with the name

Bioni Hygienic Bioni CS GmbH

The sample has been selected by Bioni CS GmbH as being representative.

The emissions were tested according to the AgBB-scheme (AgBB - Committee for Health-related Evaluation of Building Products). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11, ISO 16017-1 in the latest versions, see the test report no. 759041D.

Evaluation of the test result according to AgBB guidelines:

- Carcinogenic substances were not detectable after 3 and after 28 days.
 - The sum of VOC ("TVOC") after 3 days was below the limit of 10 mg/m³.
 - The sum of VOC ("TVOC") after 28 days was below the limit of 1 mg/m³.
 - The sum of SVOC after 28 day was below the limit of 0.1 mg/m³.
 - After 28 days the value R was calculated from the detected VOC with single concentrations above 5 µg/m³. This value R was below the limit of 1.
 - The sum of VOC without LCI-value after 28 days was below the limit of 0.1 mg/m³.
 - Formaldehyde after 28 days was below 120 µg/m³.
-

The tested product complies with the requirements of AgBB (September 2005) for use in the indoor environment.

15 October 2007



Thomas Neuhaus
Head of product emission test centre



Inge Bondgaard
M.Sc. (Chemistry)

Eurofins Environment A/S
Smedeskovvej 38
DK-8464 Galten /
Denmark

Tel +45 70 22 42 66
Fax +45 70 22 42 55